

Noise Modelling Results

Receptor	Rule 012 Permissible Sound Level [dBA]		Cumulative Noise Level [dBA]		Margin of Compliance [dBA]	
	Daytime	Nighttime	Daytime	Nighttime	Daytime	Nighttime
R22	50	40	45	37	5	3
R23	50	40	46	39	4	1
R24	50	40	45	37	5	3
R27	50	40	46	38	4	2
R28	50	40	45	37	5	3
R31	50	40	45	37	5	3
R32	50	40	45	38	5	2
R34	50	40	45	38	5	2
R35	50	40	46	38	4	2
R38	50	40	45	38	5	2
R41	55	45	50	42	5	3
R43	55	45	50	42	5	3
R44	55	45	50	42	5	3
R45	55	45	50	42	5	3
R47	50	40	45	38	5	2
R48	50	40	45	38	5	2
R52	50	40	45	38	5	2
R54	50	40	46	38	4	2
R57	50	40	45	37	5	3
R62	50	40	46	40	4	0
R63	50	40	46	38	4	2
R66	50	40	46	39	4	1
R67	50	40	46	38	4	2
R70	50	40	45	38	5	2
R73	50	40	46	38	4	2
R73a	50	40	46	38	4	2
R87	50	40	46	40	4	0
R88	50	40	46	40	4	0

Note: Margin of compliance is the numerical difference between the Rule 012 permissible sound level and the cumulative noise level.